

APR 21 1981

SITE: Florida Phosphate
BREAK: 17.8
OTHER: v. 20

APRIL 20 1981

MR DON GUTHRIE
POLK COUNTY HEALTH DEPARTMENT
229 AVE D NW
WINTER HAVEN, FL 33880

RE: GUNTER HOMES
NEW PROJECT
LAKE CANYON
LAKELAND

DEAR MR GUTHRIE

AS ARCHITECT FOR THIS PROJECT, WE AND THE BUILDER
SHALL COMPLY WITH YOUR REQUIREMENTS AS FOLLOWS:

1. PROPERLY DESIGN STRUCTURAL MONOTHLIC SLABS
2. EACH UNIT TO HAVE AN ELECTRONIC AIR CLEANER
3. BUILDER AGREES TO PERIODIC ON SITE INSPECTIONS
4. BUILDER WILL NOTIFY PCHD AFTER FIRST POUR
5. BUILDER WILL PERMIT ON SITE INSPECTION ANY TIME
6. FURNISH PCHD WITH SLAB DESIGNER AND DESIGN
7. SPECIFY 3000PSI CONCRETE AND 6"THICK GROUND SLABS

PLEASE REVIEW AND ADVISE
THANK YOU,


AKENDRICK REGNVALL

AKR/KR



10517222

Kendrick Regnval Architects
211 SOUTH TENNESSEE AVENUE
LAKE LAND, FLORIDA 33801
(813) 687-3573